



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 58 Pt.20 T/J(27)

14 August 2025

Nomura Fiberglass Ltd.
G/F, No.20 Wo Ping San Tsuen,
Hung Shui Kiu, Yuen Long,
N.T., Hong Kong

(Attn.: Mr Freddy TAM)

Dear Sir,

**Approval of "NOMURA" Fiberglass Water Tanks
(General Acceptance No. ZM20250017)**

Your E-Application [file-id: ETJ-GA-20250717-185] dated 18 July 2025 and subsequent submission received by this department on 29 July 2025 refer.

Having considered the test report ref. AGA50149B issued on 29 July 2025 by ETS-Testconsult Limited, this Authority accepts that the material described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Nomura Fiberglass

Country of Origin: the Mainland of China

Brand: Nomura

Details of Material: Fiberglass water tanks with water volume (0.05m³ to 500m³) assembled from the following cream colour GRP panels.

Model No.	Panel Size (m)
P 0.9 x 0.9	0.9 x 0.9 x 0.085
P 1.2 x 1.2	1.2 x 1.2 x 0.085
P 0.5 x 1	0.5 x 1 x 0.085

Model No.	Panel Size (m)
P 0.75 x 1	0.75 x 1 x 0.085
P 1 x 1	1 x 1 x 0.085
P 0.5 x 1.5	0.5 x 1.5 x 0.085
P 0.75 x 1.5	0.75 x 1.5 x 0.085
P 1 x 1.5	1 x 1.5 x 0.085
P 0.5 x 2	0.5 x 2 x 0.085
P 0.75 x 2	0.75 x 2 x 0.085
P 1 x 2	1 x 2 x 0.085
P 0.75 x 2.5	0.75 x 2.5 x 0.085
P 1 x 2.5	1 x 2.5 x 0.085
SP 0.1 – 3	(0.1m – 2m) x (0.1m – 3m) x 0.085m
SS 0.1 - 3	(0.1m – 2m) x (0.1m – 3m) x 0.005m
CP 0.5 - 10	Ø0.5m – Ø10m x 0.5m(H) – 4m(H)

List of tanks:

Package Type Water Tank Model	Size (ft)
HF 1.5 x 1.5 x 1.5	1.5 x 1.5 x 1.5
HF 2 x 2 x 2	2 x 2 x 2
HF 3 x 2 x 2	3 x 2 x 2
HF 2 x 2 x 3	2 x 2 x 3
HF 3 x 2 x 3	3 x 2 x 3
HF 3 x 3 x 3	3 x 3 x 3
HF 3 x 3 x 4	3 x 3 x 4
HF 4 x 3 x 4	4 x 3 x 4
HF 4 x 4 x 4	4 x 4 x 4

Body Markings:



Expiry Date:

13 August 2030

This Authority hereby permits the use of the above materials in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the materials to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the materials installed fails to meet that of the approved samples or if the materials are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the materials in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the materials by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only